

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
66742	Land east of Colthrop Industrial Estate, Thatcham (Site Ref: MID5)	396000	4.58	370	80000	2.78	229	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	The scale of development/s is likely to require upgrades to both the wastewater network and sewage treatment infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on the network and treatment infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development . Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
63982	Land west of Ramsbury Road, Membury Industrial Estate, Lambourn Woodlands	205543.8	2.38	192	41524	1.44	119	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
74337	Land to the south of Trinity Grain, Membury Industrial Estate, Lambourn Woodlands	102960	1.19	96	20800	0.72	59	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
74339	Beenham Landfill, Pips Way, Beenham	277200	3.21	259	56000	1.94	160	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	The scale of development/s is likely to require upgrades to both the wastewater network and sewage treatment infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on the network and treatment infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development . Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
69375	BEEN10- Northway Porsche, Grange Lane, Beenham	126720	1.47	119	25600	0.89	73	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	The scale of development/s is likely to require upgrades to both the wastewater network and sewage treatment infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on the network and treatment infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development . Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
61427	Land adjacent to Padworth IWMF, Padworth Lane, Padworth (Site Ref: PAD4)	245520	2.84	230	49600	1.72	142	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	The scale of development/s is likely to require upgrades to both the wastewater network and sewage treatment infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on the network and treatment infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development . Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
40790	Land north of Newbury College, Monks Lane, Newbury (Site ref HSA 1))	16038	0.19	15	5250	0.18	15	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
41285	EMP1 Whitehart Meadow, Theale	42768	0.5	40	14000	0.49	40	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
40830	Former Theale Sewage Treatment Works, Theale (Site Ref THE7)	64152	0.74	60	21000	0.73	60	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
40849	Land adjoining Pondhouse Farm, Clayhill Road, Burghfield Common (Site Ref: HSA15)	106920	1.24	100	35000	1.22	100	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
40843	Land north of A4 Bath Road, Woolhampton	17107.2	0.2	16	5600	0.19	16	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
41821	RSA 22 Land adjoining Lynch Lane, Lambourn (Site Ref: HSA 19)	64152	0.74	60	21000	0.73	60	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
48917	Land at Newbury Road, Lambourn (Site Ref: HSA 20)	5346	0.06	5	1750	0.06	5	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
40855	Land North of Southend Road, Bradfield Southend (Site Ref: BRAD5)	21384	0.25	20	7000	0.24	20	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
68015	Land at Chieveley Glebe, Chieveley (Site Ref: CHI23)	16038	0.19	15	5250	0.18	15	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
40861	Pirbright Institute Site, High Street, Compton (Site Ref: HSA 22)	149688	1.73	140	49000	1.7	140	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	PFC Calc for proposed development advises Low to No Risk. Pipe Capacity Calc = 7.6 % based on connection to 150mm dia FW Sewer located in Churn Road. GM 14/02/2023
61416	Land west of Spring Meadows, Great Shefford (Site Ref: GS1)	16038	0.19	15	5250	0.18	15	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
40802	Land at Bath Road, Speen, Newbury, Berkshire, RG14 8AA (approved feb 2020)	106920	1.24	100	35000	1.22	100	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
40863	Land off Charlotte Close, Hermitage (Site Ref: HSA 24)	16038	0.19	15	5250	0.18	15	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
40864	Land to the south east of the Old Farmhouse, Hermitage (Site Ref HSA 25)	10692	0.12	10	3500	0.12	10	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase - Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
74336	Land adjacent Station Road, Hermitage	36352.8	0.42	34	11900	0.41	34	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
40874	Land adjoining The Haven, Kintbury (Site Ref: KIN6)	21384	0.25	20	7000	0.24	20	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
68016	RSA 32 New Stocks Farm, Paices Hill, Aldermaston (Site Ref: TS1)	11880	0.14	11	2880	0.1	8	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
68017	Long Copse Farm, Enborne (Site Ref: TS2)	35640	0.41	33	8640	0.3	25	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
40805	Land at Coley Farm, Stoney Lane, Newbury (Site Ref: HSA 3) (SITE ALLOCATED PENDING)	80190	0.93	75	26250	0.91	75	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
41814	Land off Greenham Road, South East Newbury (Site Refs: HSA 4)	171072	1.98	160	56000	1.94	160	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	The scale of development/s is likely to require upgrades to both the wastewater network and sewage treatment infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on the network and treatment infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development . Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
40820	Land at Lower Way, Thatcham (Site Ref: THA025)	90882	1.05	85	29750	1.03	85	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
40899	Stoneham's Farm, Long Lane, Tilehurst (Site Ref: HSA 9)	0	0	0	0	0	0	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
40897	72 Purley Rise, Purley on Thames (Site Ref HSA 11)	37422	0.43	35	12250	0.43	35	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
40892	Land adjacent to Bath Road and Dorking Way, Calcot (Site Ref HSA 13)	37422	0.43	35	12250	0.43	35	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	The scale of development/s is likely to require upgrades to both the wastewater network and sewage treatment infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on the network and treatment infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development . Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
40841	Land between A340 and The Green, Theale (Site Ref: HSA 14)	106920	1.24	100	35000	1.22	100	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	On the information available to date we do not envisage infrastructure concerns regarding wastewater network or wastewater treatment infrastructure capability in relation to this site/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.

Site ID	Site Name	Net Gain to System (l/day)	Net Foul Water Increase to System (l/s)	Net Property Equivalent Increase Waste	Net Increase in Demand (l/day)	Net Increase in Peak Demand (l/s)	Net Property Equivalent Increase - Water	Water Response	Waste Response	Additional Comments
41427	Sandleford Park, Newtown Road, Newtown, Newbury, Berkshire (PENDING)	1603800	18.56	1500	525000	18.23	1500	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	The scale of development/s is likely to require upgrades to both the wastewater network and sewage treatment infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on the network and treatment infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development . Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer.
62237	North East Thatcham Strategic Site Allocation	1640100	18.98	1534	530500	18.42	1516	The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development .	The scale of development/s is likely to require upgrades to both the wastewater network and sewage treatment infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on the network and treatment infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development . Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	These comments are based on foul flows connecting to the public sewer by gravity (not pumped) and no surface water flows being discharged to the public sewer. If this site in total is to produce 2500 homes, our comments remain the same.